

City of Camanche Water Quality Information 2019

This document is to inform you of the quality of the drinking water supplied to you last year. Included are details about where the water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and State Standards. We are committed to providing you with information.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as persons with cancer, undergoing chemotherapy, persons who have organ transplants, people with HIV/AIDS or other immune disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk from infections by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and children. The lead in your drinking water comes mainly from materials used in the plumbing and service lines in your home. The City of Camanche is responsible for providing high quality drinking water, but cannot control the variety of materials used in your homes plumbing. If your water has set for several hours you can minimize possible lead exposure by flushing your water 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water you may want to have it tested. For more information on lead in your drinking water please call the Safe Drinking Water Hotline 800-426-4791 or at <http://www.epa.gov/safewater/lead>. Drinking water including bottled water may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

In order to ensure that tap water is safe to drink, the EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems.

We treat our water according to EPA and the state of Iowa regulations. The Food and Drug Administration establishes limits for contaminants in bottled water that must provide the same protection for public health.

In 2019 the City of Camanche provided 94.3 Million gallons of drinking water to the community. With 68.0% of the water came from well # 6, 14.10% came from well # 3 and 17.68% from well #5. And one stand-by well the produced 0.22%

The City owns the land around these wells and restricts any activity that could contaminant them. After the water comes out of the wells we add disinfectant to protect you against microbial contaminants. A chemical known as polyphosphate is also added to sequester any iron that may be present in the water

Results of testing performed for contaminants:

CONTAMINANT	MCL-(MCLG)	Compliance		Date	Violation Yes/NO	Source
		Type	Value & (Range)			
Total Trihalomethanes (ppb) [TTHM]	80 (N/A)	LRAA	13.00 (13-13)	9/30/2019	NO	By-products of drinking water chlorination
Copper (ppm)	AL=1.3 (1.3)	90th	0.268 (0.0111-0.617)	2018	NO	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (ppb)	AL=15 (0)	90th	0.00 (ND - 2)	2018	NO	Corrosion of household plumbing systems; erosion of natural microbes
950-DISTRIBUTION SYSTEM						
Chlorine (ppm)	MRDL=4.0 MRDLG=4.0	RAA	0.78 (0.5 - 2)	12/31/2019	NO	Water additive used to control microbes
03 - S/EP WELL #5						
Sodium (ppm)	N/A (N/A)	SGL	54	7/11/2017	NO	Erosion of natural deposits; Added to water during treatment process
04 - S/EP WELL #6						
Arsenic (ppb)	10 (0)	SGL	2.00	7/13/2015	NO	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronic production waste
Barium (ppm)	2 (2)	SGL	0.11	7/13/2015	NO	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Sodium (ppm)	N/A (N/A)	SGL	37	8/21/2018	NO	Erosion of natural deposits; Added to water during treatment process
Nitrate [as N] (ppm)	10 (10)	SGL	4	2019	NO	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
06 - S/EP WELL #3						
Sodium (ppm)	N/A (N/A)	SGL	57	8/14/2019	NO	Erosion of Natural deposits; Added to water during treatment process
Nitrate [as N] (ppm)	10 (10)	SGL	4.6	2019	NO	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Note: Contaminants with dates indicate results from the most recent testing done in accordance with regulations

Terms used when expressing results for detection of contaminants in drinking water

mg/l - milligram per litre

ppm - parts per million

ppb - parts per billion

MCL - Maximum Contaminant Level-The maximum allowable contaminants level allowed in drinking water.

AL - Action Level- The concentration of a contaminant which if exceeded, triggers treatment or other requirements which a water system must follow

MCLG - Maximum Contaminant Level Goal, the level of a contaminant in drinking water which there is no known or expected risk to health.

MCLG's allow for a margin of safety

MRDLG - Maximum Residual Disinfectant Level Goal-The level of a drinking water disinfectant below which there is no know or expectant risk to health MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants

pCi/L - picocuries per liter

LRAA - Locational Running Annual Average: RAA-Running Annual Average: SGL-Single Sample Result: N/A-Not Applicable: ND-Not Detected

This water supply obtains its water from the sand and gravel Alluvial aquifer. The Alluvial aquifer was determined to be highly susceptible to contamination because the characteristics of the aquifer and overlying materials provide little protection from contamination at the land surface. The Alluvial wells will be highly susceptible to surface contamination such as leaking underground storage tanks, contaminant spills, and excess fertilizer application. A detailed evaluation of your source water was completed by the Iowa DNR and is available from the Water Operator at 563-259-9410.

This water supply also obtains water from the sandstone and dolomite of the *Cambrian-Ordovician* aquifer. The *Cambrian-Ordovician* aquifer was determined to be slightly susceptible to contamination because the characteristics of the aquifer and overlying materials provide moderate protection from contamination at the land surface. The *Cambrian-Ordovician* well will be slightly susceptible to surface contamination such as leaking underground storage tanks, contaminant spills, and excess fertilizer application. A detailed evaluation of your source water was completed by the Iowa DNR and is available from the Water Operator at 563-259-9410

Addition Health Information

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for a short period of time because of rainfall or agricultural activity. Contact your health care professional for more information.

Source Water Violation

In September 2019 our water system violated a drinking water standard. Even though these were not emergencies, as our customers, you have the right to know what happened and what we did to correct these situations.

We, The City of Camanche, Iowa Public Water Supply are required to monitor your drinking water for a specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 2019 a nitrate sample was to be sent into the Lab for testing between July 1 and Sept 30th on August 14th 2019 the sample was sent to the lab and was delayed in delivery, when it did reach the lab, time has expired for an accurate test. The deadline had expired and we sent in a replacement sample. A new sample was sent in and test came back with safe levels and monitoring procedures have been corrected to avoid future violations

Contact Information:

If you have questions or comments about your drinking water, please call the CAMANCHE WATER SUPPLY at 259-9410. This report will not be mailed to you, please call us if you would like a copy.